



# Inspection Report 4

Date: May 19, 2017	Site Address: 4700 Keele St. – Farquharson Life Science	Reveal Project No: 2017037
Client: York University	Contractor: Gillam Group.	Inspector: Jeff Lainsbury
Number of workers: N/A		Time of Inspection: 11:00 AM

## Distribution:

Name	Company	Email
Earnest Murdoch	Gillam Group	<a href="mailto:emurdoch@gillamgroup.com">emurdoch@gillamgroup.com</a>
Adriano Morassutti	York University	<a href="mailto:adrianom@yorku.ca">adrianom@yorku.ca</a>
Devin Ricalis	Priestly Demolition	<a href="mailto:dricalis@priestly.ca">dricalis@priestly.ca</a>

## Work Inspected:

Location	Description of Work
Room 107	Occupied Air Sampling
Room 204	Occupied Air Sampling
Room 306	Occupied Air Sampling

## Air Samples:

Sample #	Type	Location	Start Time	Flow (L/min)	Duration (minutes)	Volume (L)	Result (fibre/cc)
001	Occupied	Room 107	11:28	15	25	375	<0.05
002	Occupied	Room 204	11:08	15	27	405	<0.05
003	Occupied	Room 306	11:23	15	25	375	<0.05
004	Blank		N/A	N/A	N/A	N/A	1 Fibre

## Inspection Notes:

Item	Description
<b>1.0</b>	<b>Sampling</b>
1.1	All sample results are below the action limit of 0.05 fibres/cc, therefore no further action is required.
1.2	Occupied air sampling is routinely performed in occupied areas adjacent to asbestos abatement work to ensure that occupied areas are unaffected by the abatement activities.