



Inspection Report 6

Date: June 22, 2017	Site Address: 4700 Keele St. – Farquharson Life Science	Reveal Project No: 2017025
Client: York University	Contractor: Priestly	Inspector: Jeff Lainsbury
Number of workers: N/A		Time of Inspection: 11:00 AM

Distribution:

Name	Company	Email
Earnest Murdoch	Gillam Group	emurdoch@gillamgroup.com
Adriano Morassutti	York University	adrianom@yorku.ca
Devin Ricalis	Priestly Demolition	dricalis@priestly.ca

Work Inspected:

Location	Description of Work
West Wing	Occupied Air monitoring

Air Samples:

Sample #	Type	Location	Start Time	Flow (L/min)	Duration (minutes)	Volume (L)	Result (fibre/cc)
001	Occupied	Corridor outside Rm 043	11:30	15	31	465	<0.05
002	Occupied	Rm 103	11:36	15	26	390	<0.05
003	Occupied	Rm 211	11:40	15	27	405	<0.05
004	Occupied	Rm 306	11:47	15	26	390	<0.05

Inspection Notes:

Item	Description
1.0	Sampling
1.1	All occupied air samples collected from the occupied west wing of the building are acceptable for occupied areas.
1.2	Additional air sampling to be performed next week.