

Inspection Report 7

| | | |
|-------------------------|---|-----------------------------|
| Date: June 30, 2017 | Site Address: 4700 Keele St. – Farquharson Life Science | Reveal Project No: 2017025 |
| Client: York University | Contractor: Priestly | Inspector: Jeff Lainsbury |
| Number of workers: N/A | | Time of Inspection: 7:30 AM |

Distribution:

| Name | Company | Email |
|--------------------|---------------------|--|
| Earnest Murdoch | Gillam Group | emurdoch@gillamgroup.com |
| Adriano Morassutti | York University | adrianom@yorku.ca |
| Devin Ricalis | Priestly Demolition | dricalis@priestly.ca |

Work Inspected:

| Location | Description of Work |
|-----------|-------------------------|
| West Wing | Occupied Air monitoring |
| | |
| | |
| | |

Air Samples:

| Sample # | Type | Location | Start Time | Flow (L/min) | Duration (minutes) | Volume (L) | Result (fibre/cc) |
|----------|----------|-------------------------|------------|--------------|--------------------|------------|-------------------|
| 001 | Occupied | Corridor outside Rm 043 | 10:33 | 15 | 24 | 360 | <0.05 |
| 002 | Occupied | Rm 104 | 10:38 | 15 | 24 | 360 | <0.05 |
| 003 | Occupied | Rm 204 | 10:44 | 15 | 24 | 360 | <0.05 |
| 004 | Occupied | Rm 304 | 10:50 | 15 | 24 | 390 | <0.05 |

Inspection Notes:

| Item | Description |
|------------|---|
| 1.0 | Sampling |
| 1.1 | All occupied air samples collected from the occupied west wing of the building are acceptable for occupied areas. |
| 1.2 | Additional air sampling to be performed next week. |